Hyun Jin Lim and Per F. Peterson U.C. Berkeley Report UCBTH-09-005

May 20, 2009

Introduction

UC Berkeley has developed the PB-AHTR (Pebble Bed Advanced High Temperature Reactor) as shown in Fig. 1 [1]. The PB-AHTR uses an intermediate heat transport system to transfer the heat from reactor to power conversion system or hydrogen production system.

The modular PB-AHTR (900 MWth) adopts several components and systems that were originally developed for the Molten Salt Breeder Reactor (MSBR) program at ORNL. These include the MSBR primary pump and intermediate heat exchanger (IHX) developed and tested at multiple scales in the ORNL MSBR program [1, 2].

Several types of heat exchangers, compact plate types and shell-and-tube types, were considered for use as the PB-AHTR the IHX. To facilitate in-service inspection and reliability, the PB-AHTR adopts the MSBR shell and tube IHX design [1, 2]. There are four IHX (225 MWth/IHX) and two primary pump in the intermediate loop and each of the two primary salt pumps provides flow to two of the four IHX's. Figure 2 provides a cross sectional elevation view of IHX for the PB-AHTR.



Fig. 1. Schematic of the modular PB-AHTR



Fig. 2. Elevation view of IHX for the PB-AHTR, with inlet and outlet plenums shown schematically.

The overall conditions in the PB-AHTR system impose several specific design requirements on the IHX's [3]:

- 1. The entrance and exit coolant temperatures, maximum pressure drop and the total heat transfer capacity must conform to the overall system operating conditions.
- 2. The type of heat exchanger, general location of nozzle, height of the unit and minimum tube diameter must be compatible with various design, layout and fabrication considerations.
- 3. The heat exchanger must be arranged for relatively easy tube-bundle replacement by means of remote operation.
- 4. Flow velocities, baffle thickness, tube clearance and baffle spacing should be selected to minimize possibilities of vibration.

Based on the conditions, for application to the PB-AHTR the detailed design characteristics for shell-and-tube-type, one-pass vertical exchanger with disk-and-doughnut-baffles heat exchangers are [3]:

- 1. The tubes are arranged in concentric rings in the bundle and the L-shaped tubes are welded into a tube sheet. The L-shaped tubes help accommodate differential thermal expansion between tubes.
- 2. The tubes have a helically knurled surface to improve heat transfer and to minimize salt volume. The tubes may also have a tri-clad construction, with a high-temperature structural alloy sandwiched between thin layers of a corrosion resistant cladding material.
- 3. The baffles are used to hold the tubes and to control cross flow to minimize the flow-induced vibration.
- 4. The IHX should facilitate natural circulation flow. Thus the primary salt must flow downward and the intermediate coolant upward.
- 5. The primary coolant must enter and exit from the top of the IHX, because the connections on the primary loop of the PB-AHTR, which uses a pool-type reactor vessel and a guard vessel, are also high in the system.
- 6. Under this configuration, the primary coolant flows on the tube side and the intermediate coolant enters from the bottom, flows on the shell side, and exits the top.

The primary salt (flibe) enters the top of the IHX tube side, which uses 0.9525-cm O.D., 0.1335-cm wall thickness tubes with an inlet temperature of 704° C, exits the bottom tube sheet into a collection plenum, and then flows upward through central pipe and out from the top of IHX at a temperature of 600° C. The secondary salt (flinak) enters the bottom of IHX shell side at a temperature of 545° C and flow upward around disk and doughnut type baffles, and flow out the top of IHX at 690° C. Based on the requirements, the design calculations were performed using the PRIMEX code.

Description of the PRIMEX code

PRIMEX (PRIMary heat EXchanger) is a computer code which was developed at ORNL in 1971 for MSBR primary heat exchanger design [4]. In the MSBR design, the PRIMEX code was believed to result in an efficient and reliable design.

In 1998, the code was reconstructed at Ajou University (South Korea) as a part of development of an advanced molten salt nuclear energy complex, named AMBIDEXTER [5]. Most of the modification of the code was to meet PC operating system requirements, thus the code was updated from the original version of IBM 360/91 to MS WINDOWS. Table 1 provides a brief history of the code development and modifications.

year	Institute	Modifications
1971	ORNL (MSBR)	Original code development, IBM 360/91
1998	Ajou Univ. (AMBIDEXTER)	Code reconstruction for PC WINDOWS
2008	UC Berkeley (PB-AHTR)	Physical Properties (flibe, flinak) insertion

Table 1. Development and update history of the PRIMEX code [4,5]

A simplified flow diagram for the PRIMEX code and the definition of baffle space are shown in Figs. 3 and 4, respectively. In the code calculation, each zone between two baffles was considered as one increment length. The calculations are begun on the hot side of the heat exchanger, and increments are added until a complete heat balance is achieved [5].



Fig. 3. The simplified flow diagram for the PRIMEX code



Fig. 4. The baffle space in the PRIMEX code

Design Calculations

The physical properties of the salts are given by temperature dependent equations and these equations are can be replaced when the salt types are changed. The physical properties of primary and secondary salts for the heat exchangers in the AMBIDEXTER are same as the MSBR. But the PB-AHTR case, to the properties are changed to use flibe (primary) and flinak (secondary) as the salts. The salt properties used for the PB-AHTR IHX design are listed in table 2 [6].

Heat transfer experience with the salts is limited because no experiments have been performed for correlating the heat transfer behavior of coolant salt in the shell side of the heat exchanger, but the MSRE and some experiments showed that basically the primary salt (fuel salt in MSRE) behaves very similarly to conventional fluids [3].

As described earlier, the tubes in the heat exchanger are helically indented to improve heat transfer performance. Some experimental results performed by C. G. Lawsin, et al. [7] indicate that this indentation is expected to result in an improvement by a factor of 2 in the tube-side heat transfer coefficient. For the tube outside, an enhancement factor of 1.3 was recommended but it was based on some assumptions [3].

	Melting point (°C)	Density (g/cm ³)	Heat capacity (J/kg K)	Viscosity (cP)	Th. conductivity (W/m K)	Pr (at T=600° C)
LiF-BeF ₂ (66-34)	458	$2.28 - 4.884E - 4 \times T$	2380	$0.116\exp\left(\frac{3755}{T+273}\right)$	1.1	20.4
NaF- NaBF ₄ (8-92)	385	$2.2521 - 7.11E - 4 \times T$	1500	$0.0877\exp\left(\frac{2240}{T+273}\right)$	0.5	3.4
LiF- NaF-KF (flinak)	454	$2.53 - 7.3E - 4 \times T$	1880	$0.04\exp\left(\frac{4170}{T+273}\right)$	1	10

 Table 2.
 Summary of properties of the primary and secondary salts [6]

In the code calculation, the overall heat transfer coefficient, U_0 , is given by

$$U_{O} = \frac{1}{\frac{1}{h_{O}} + \frac{1}{h_{W}} + \frac{1}{h_{i}} \left(\frac{d_{O}}{d_{i}}\right)}$$
(1)

where for turbulent flow,

$$\frac{h_i d_i}{k_i} = 0.217 \left(Re \right)^{0.8} \left(Pr \right)^{0.33} \left(\frac{\mu_b}{\mu_i} \right)^{0.14} \left(EF_i \right)$$
(1-a)

$$h_{W} = \left(\frac{k}{d_{o}t}\right) \frac{d_{o} - d_{i}}{\ln \frac{d_{o}}{d_{i}}}$$
(1-b)

$$\frac{h_O d_O}{k_O} = 0.128 \left(D_{eq} \right)^{.6} \left(Re \right)^{0.6} \left(Pr \right)^{0.33} \left(\frac{\mu_b}{\mu_i} \right)^{0.14} \left(EF_O \right)$$
(1-c)

The enhancement factors, EF_i and EF_o , are

$$EF_i = 2.0$$
 and $EF_o = 1.3$ for Reynolds numbers $(Re) \ge 10,000$
 $EF_i = 1.0$ and $EF_o = 1.0$ for Reynolds numbers $(Re) \le 1,000$

For $1,000 \le \text{Re} \le 10,000$,

$$EF_i = 1.0 + \left(\frac{Re - 1000}{9000}\right)^{0.5}$$
 and (1-d)

$$EF_o = 1.0 + 0.3 \left(\frac{Re - 1000}{9000}\right)^{0.5}$$
(1-e)

The pressure drop at the inside tubes (ΔP_i) is calculated by

$$\Delta P_i = f \frac{L}{D_i} \frac{\rho V^2}{2} (EF_i)$$
⁽²⁾

and the pressure drops for the shell side with baffle region are calculated for the cross-flow zone and the window zone. The pressure drop for the cross-flow zone is

$$\Delta P_{cross-flow} = 0.6r_B \frac{\rho V_m^2}{2} (PLF) (EF)$$
(3)

and the pressure drop at the window zone is calculated by

$$\Delta P_{window} = (1 + 0.6r_w) \frac{\rho V_z^2}{2} (PLF) (EF)$$
(4)

Calculation Result and Analysis

Similar to commercial heat exchanger design codes, total heat capacity, inlet-outlet temperatures of primary and secondary coolant, tube diameter, IHX shell diameter and maximum pressure drops in the tube and shell sides are required as main input parameters for the PRIMEX calculation. Also, British Thermal Units (BTU) are used in the code.

Among the input data which significantly affect the heat exchanger design are the physical properties of salts and their variation with temperature, the heat transfer correlations, the enhancement factors assumed for the knurled tubes and the leakage factors associated with fabrication clearances [4].

Once the inlet and outlet temperatures of the primary and secondary salts are determined, the maximum pressure drop and allowable IHX diameter are the major input parameters to determine the tube length and shell diameter of the IHX [3].

For the baseline IHX design for the PB-AHTR, a lower LMTD is desired than was used in the MSBR to increase the power conversion efficiency and thus a substantially larger surface area is used comparing the MSBR case, as shown in Fig. 5 [6]

Initial calculations were performed with some different shell diameter and tube length cases. As the result, the optimal inlet temperature for the intermediate salt will be around the 550°C value and it is clear that shorter IHX designs have lower effectiveness and thus require more surface area to achieve the same LMTD. On the other hand, shorter IHX designs have smaller pressure drop, which is also valuable. In all cases the primary salt volume in the tubes was relatively small compared to the total primary salt volume.



Fig. 5. Primary salt, intermediate salt, and power conversion fluid temperatures in the MSBR IHX and the PB-AHTR IHX

Table 3 shows the calculation results for the IHX. There are three candidate approaches to meet the physical arrangement with reactor vessel and primary loop for the PB-AHTR plant [6]. From the perspective of the physical arrangement, there is no difference between the 1.98-m diameter and the 2.35-m diameter designs, since this difference is very small compared to the distances needed between the IHX's and the reactor vessel.

The IHX height is a more important parameter, since it varies more, but the current reactor design can likely accommodate the full range of optimized lengths with minor impacts. Thus the IHX can be optimized independently from the physical arrangement.

Fig. 6 shows the 3-D view for the PB-AHTR primary loop arrangement and the baseline IHX design with 8.54-m long tubes and a 2.16-m shell diameter. The physical arrangement was developed by U.C. Berkeley seniors in the 2008 NE-170 senior design class [8].



Fig. 6. The 3-D drawings of the PB-AHTR primary loop and the baseline IHX design [8].

Туре	Shell-and-tube one-pass vertical exchanger with disk and doughnut baffles			
Number of required	Four			
Heat transfer rate per unit (MWth)		225.0		
Primary salt	t	flibe (Li ₂ BeF ₄))	
Secondary salt	fina	ak (LiF-NaF-H	KF)	
Tube Material	Tri-clad A	Alloy 800H/Ha	astelloy N	
Inlet temperature of primary salt (°C)		704.0		
Outlet temperature of primary salt (°C)		600.0		
Inlet temperature of secondary salt (°C)		545.0		
Outlet temperature of secondary salt (°C)		690.0		
Outside diameter of tubes (cm)		0.9525		
Wall thickness of tubes (cm)		0.1335		
Mass flow rate of primary salt (kg/sec)	905.87			
Mass flow rate of secondary salt (kg/sec)	823.60			
Central tube(up-comer) diameter (cm)		55.0		
Wall thickness of IHX shell(cm)	1.27			
Total tube length(m)	9.36	8.54	7.99	
Total number of tubes	7822	9465	11249	
IHX approx. length(m)	8.80	7.98	7.39	
Nominal IHX diameter (m)	1.98	2.16	2.35	
Primary salt volume in tubes(m ³)	2.70	2.99	3.32	
Total heat transfer area based on tube $O.D(m^2)$	2194.20	2418.99	2695.30	
Tube side avg. heat transfer coeff. $(W/m^2 \circ C)$	7997.84	6556.83	5474.00	
Shell side avg. heat transfer coeff. (W/ m ² °C)	12943.56	11992.93	10853.75	
Pressure drop in tube side (bar)	2.20	1.39	0.93	
Pressure drop in shell side (bar)	1.90	1.43	0.95	
Total mass of tubes per IHX module (kg)*	22438.12	24772.59	27543.68	
Approx. total mass of IHX module (kg) **	29170.00	32204.00	35806.00	
Uniform baffle spacing (m)	0.183	0.192	0.210	

Table 3. Design Data for PB-AHTR IHX, for 3 different point designs with different average tube lengths.

*, ** Cold state (at 26°C) mass, primary and secondary salt masses are not included. ** The total mass of the IHX is assumed to be 130% of the tube mass. Four modules provide a total capacity of 900 MWth.

Conclusion and Remarks

This report describes the design requirements and PRIMEX code results for the PB-AHTR IHX modules. The baseline 900-MWth reactor design has four IHX modules with 8.54-m long tubes and 2.16-m diameter shells. The IHX design data is summarized in Table 3 and can used for the transient analyses of the PB-AHTR.

The calculation results from the PRIMEX code will result in more reliable design to minimize the volume of primary salt and structural materials, compared to what can be achieved by normal hand calculations. Also, the code can be applied in the future for the design of the PB-AHTR Direct Reactor Auxiliary Cooling System heat exchangers (DHXs).

However, the some models and input data that have a significant effect on the design of IHX still involve significant uncertainties: the heat transfer correlations, the enhancement factors for the helically indented tubes, the baffle leakage factors related to the fabrication clearance, etc. Also, more detailed design and verification are required for the detailed design stage of the PB-AHTR. Test data from a reduced-area, reduced length IHX from a Liquid Salt Component Test Facility would be helpful in validating these models and input data.

Nomenclature

h_i	heat transfer coefficient inside tube, Btu/hr·ft ² .°F
h_{w}	heat transfer coefficient across the tube wall, Btu/hr $\cdot ft^2 \cdot {}^\circ F$
h_o	heat transfer coefficient outside tube, Btu/hr·ft ² .°F
d_i	tube inside diameter, ft
d_o	tube outside diameter, ft
<i>k</i> _i	thermal conductivity of fluid inside tube, Btu/hr·ft·°F
k	thermal conductivity of tube wall, Btu/hr·ft·°F
k_o	thermal conductivity of fluid out tube, Btu/hr·ft·°F
t	tube wall thickness, ft
Re	Reynolds number
Pr	Prandtl number
μ_b	viscosity at temperature of bulk fluid, lb/ hr ft
μ_i	viscosity of fluid at temperature of inside surface of tube, lb/ hr \cdot ft
r _B	number of cross-flow restrictios
ρ	density of fluid, lb/ft3
V	flow velocity in the tube side, ft/sec

- V_m cross-flow velocity of fluid, ft/sec
- *PLF* pressure drop leakage factor taken as 0.5
- *EF* enhancement factor outside helically indented tubes taken as 1.3
- r_w number of restriction in the window zone
- V_z mean flow velocity, ft/sec

References

- 1. Philippe Bardet et al., "Design, Analysis and Development of the Modular PB-AHTR," Proceedings of ICAPP '08, Anaheim, CA USA, June 8-12, 2008.
- 2. "The Development Status of Molten-Salt Breeder Reactors," ORNL-4812, pp. 205, August 1972.
- 3. John L. Anderson et al., "Conceptual Design Study of A Single-Fluid Molten-Salt Breeder Reactor," Oak Ridge National Laboratory, ORNL-4541, June 1971.
- 4. C. E. Bettis et al., "Computer Programs for MSBR Heat Exchangers," Oak Ridge National Laboratory, ORNL TM-2815, April 1971.
- 5. Hyun Jin Lim, "Conceptual Design Study on the AMBIDEXTER Heat Transport System," M.S. Thesis, Ajou University, February 1999.
- 6. Aurelie Niquille, "Modeling and Transient Analysis for the Modular Pebble Bed Advanced High Temperature Reactor (PB-AHTR)," M.S. Report, UC Berkeley, December 2007.
- 7. C. G. Lawsin, et al., "Enhanced Heat Transfer Tube for Horizontal Condenser with Possible Application in Nuclear Power Plant Design," Transactions of the American Nuclear Society, Vol. 9, No. 2, 1966.
- D. Caron, et al., "A Modular Pebble-Bed Advanced High Temperature Reactor," NE-170 Senior Design Project, UC Berkeley Thermal Hydraulics Laboratory, Report UCBTH-08-001, May 16, 2008.

Appendix 1. PRIMEX code (Fortran Source)

PROGRAM PRIMEXPBAHTR

REAL LK, LAWO1, LAWO3, HEATL DIMENSION TFO(1000),TCI(1000),VM1(1000),VM2(1000),VWO1(1000), 1VWO3(1000), RENTO(1000), PRNTO(1000), RENSO1(1000), RENSO2(1000), 2RENSO3(1000),VM3(1000),PDSO(1000),NT(1000),BJ(3),HSO1(1000), 3HSO2(1000),HSO3(1000),AHSO(1000),HTO(1000),UOA(1000),TCO(1000), 4TFI(1000),HEAT(1000),TWDT(1000),PDTO(100),TUBLN(100),V1(100), 5V2(1000),V3(1000),VW1(1000),VW3(1000), 6R(1000), FACT(1000), TCPI(1000), TOTAL(1000), CASM(6), CTM(6), 7CWT(1000),FWT(1000),AVWT(1000) DATA CASM /18000,18000,17000,13000,6000,3500/ DATA CTM /800,900,1000,1100,1200,1300/ ***** INPUT DATA***** OPEN (2,FILE='INPUT.TXT',FORM='FORMATTED') READ (2,100) HEATL 100 FORMAT (1F10.0) READ (2,110) CTO,FTO,ETF,ETC 110 FORMAT(4F10.0) READ (2,120) PRDT, PRDS 120 FORMAT (2F10.0) READ (2,130) RA5, RA8MAX 130 FORMAT(2F10.1) **** * HEATL : Total heat load (BTU/HR)

- * PRDT : Tube side allowable Pressuree Drop (PSI)
- * PRDS : Shell "
- * CTO : Coolant Salt Outlet Temp. (F)
- * FTO : Fuel Saint Inlet Temp.
- * ETF : Fuel Salt Outlet Temp.
- * ETC : Coolant Salt Inlet Temp.
- * RA5 : RADIUS, COOLANT CENTRAL DOWNCOMER
- * RA8MAX : RADIUS, ANTICIPATED H.X OUTER

**** DEFAULT INPUT DATA ******

DTR = 0.03125	!Tube Diameter
WTHK = 0.00438	! 150% of 0.00292(MSBR Case) with Prof. Peterson
CUT3 = 0.4	
CUT4 = 0.4	
TPIN = 25920.	! Tube side Inlet Pressure (Psi)
SPOUT = 4896.	! Shell side Outlet Pressure (Psi)
LK = 0.8	
PLK = 0.52	
WCOND = 11.6	
ARC = 60.0	
KASES = 1.	
KENTB = 1.	
KTBST = 0.	
DIA = DTR	
ICNPT = 6	
RPI= 2.0*DIA	
BCPI= RPI	

1007 FORMAT(1H , 7X, 1HI, 8X, 3HCTM, 7X, 4HCASM//(4X,I5,2F12.2))

1008 FORMAT(22H HEAT LOAD REQUIRED= ,F12.0, 2X, 8H(BTU/HR))

- 1009 FORMAT(43H ALLOWABLE TOTAL TUBE-SIDE PRESSURE DROP= ,F10.0,2X,
 - 110H(LB/SQ-FT))
- 1010 FORMAT(44H ALLOWABLE TOTAL SHELL-SIDE PRESSURE DROP= ,F10.0, 12X,10H(LB/SQ-FT))

1011 FORMAT(23H TUBE INLET PRESSURE= ,F10.0, 2X, 10H(LB/SQ-FT))
1012 FORMAT(24H SHELL OUTLET PRESSURE= ,F10.0, 2X, 10H(LB/SQ-FT))
1013 FORMAT(33H HIGH TEMP. OF SHELL SIDE FLUID= ,F10.2, 2X, 3H(F))
1014 FORMAT(33H HIGH TEMP. OF TUBE SIDE FLUID= ,F10.2, 2X, 3H(F))
1015 FORMAT(32H LOW TEMP. OF TUBE SIDE FLUID= ,F10.2, 2X, 3H(F))
1016 FORMAT(32H LOW TEMP. OF SHELL SIDE FLUID= ,F10.2, 2X, 3H(F))
1017 FORMAT(32H LOW TEMP. OF SHELL SIDE FLUID= ,F10.2, 2X, 3H(F))
1018 FORMAT(32H HEAT TRANSFER LEAKAGE FACTOR= ,F10.5)
1018 FORMAT(27H PRESSURE LEAKAGE FACTOR= ,F10.5)
1019 FORMAT(35H CONDUCTIVITY OF TUBE WALL METAL= ,F10.5, 2X,

113H(BTU/HR-FT-F)) 1020 FORMAT(37H ARC OF FOUR BENDS FOR FLEXIBILITY= ,F10.5, 2X, 9H(DEG 1REES)) 1021 FORMAT(34H INSIDE RADIUS OF OUTER ANNULUS= ,F10.5, 2X, 6H(FEET)) 1022 FORMAT(41H DISTANCE BETWEEN SHELL WALL AND TUBES= ,F10.5, 2X, 6 1H(FEET)) 1023 FORMAT(49H MAXIMUM ANTICIPATED OUTER RADIUS OF EXCHANGER= 1 ,F10.5,2X,6H(FEET)) 1024 FORMAT(23H NUMBER OF CASES RUN= ,I4) 1025 FORMAT(25H USE OF ENHANCED TUBES= ,14,2X,32H(ONE IF ENHANCED TUB 1ES ARE USED)) 1026 FORMAT(1H ,36HUSE OF STRESS ANALYSIS SUBROUTINE= ,14,2X,19H(ONE 1IE TO BE USED)) 1027 FORMAT(29H OUTSIDE DIAMETER OF TUBES= ,F10.5, 2X, 6H(FEET)) 1028 FORMAT(27H WALL THICKNESS OF TUBES= ,F10.5, 2X, 6H(FEET)) 1029 FORMAT(16H RADIAL PITCH= ,F10.5, 2X, 6H(FEET)) 1030 FORMAT(25H CIRCUMFERENCIAL PITCH= ,F10.5, 2X, 6H(FEET)) 1031 FORMAT(22H INNER BAFFLE CUT3= ,F10.5, 2X, 10H(PER CENT)) 1032 FORMAT(22H INNER BAFFLE CUT4= ,F10.5, 2X, 10H(PER CENT),//) 1033 FORMAT(25H TOTAL HEAT TRANSFERED= ,F12.0,2X,8H(BTU/HR), 12X.1H(.F5.1.9H PERCENT)) 1034 FORMAT(29H MASS FLOW RATE OF COOLANT= ,F10.0,2X,7H(LB/HR)) 1035 FORMAT(26H MASS FLOW RATE OF FUEL= ,F10.0,2X,7H(LB/HR)) 1036 FORMAT(34H SHELL-SIDE TOTAL PRESSURE DROP= ,F10.2,2X,9H(LB/SQIN) 1,2X, 1H(,F5.1,9H PERCENT)) 1037 FORMAT(33H TUBE-SIDE TOTAL PRESSURE DROP= ,F10.2,2X,9H(LB/SQIN) 1,2X, 1H(,F5.1,9H PERCENT)) 1038 FORMAT(24H NOMINAL SHELL RADIUS= ,F7.4,2X,4H(FT)) 1039 FORMAT(26H UNIFORM BAFFLE SPACING= ,F7.4,2X,4H(FT)) 1040 FORMAT(40H TUBE FLUID VOLUME CONTAINED IN TUBES= ,F7.2,1X,12H(CU 1BIC FEET)) 1041 FORMAT(1H 46HTOTAL HEAT TRANSFER AREA BASED ON TUBE O.D.= , 1F12.2,2X,6H(SQFT)) 1042 FORMAT(25H TOTAL NUMBER OF TUBES= ,F6.0) 1043 FORMAT(21H TOTAL TUBE LENGTH= ,F6.2,2X,4H(FT))

1044 FORMAT(29H HEAT EXCH. APPROX. LENGTH= ,F6.2,2X,6H(FEET))

1045 FORMAT(35H STRAIGHT SECTION OF TUBE LENGTH= ,F6.2,2X,4H(FT)) 1046 FORMAT(38H RADIUS OF THERMAL EXPANSION CURVES= ,F6.2,2X,6H(FEET) 1)

1047 FORMAT(31H BERGLIN MODIFICATION FACTOR= ,F5.2)

1090 FORMAT(1H ,3X,1HI,8X,3HTCI,9X,3HTCO,9X,3HCWT,9X,3HTFI,9X,3HTFO,9X 1,3HFWT//13X,1HF,11X,1HF,11X,1HF,11X,1HF,11X,1HF,11X,1HF 2//(1X,I3,4X,6E12.4))

1091 FORMAT(1H ,3X,1HI,8X,4HTWDT,9X,2HV1,10X,2HV2,10X,2HV3,9X,3HVW1,9X 1,3HVW3//13X,1HF,21X,6HFT/SEC//(1X,I3,4X,6E12,4))

1092 FORMAT(1H ,3X,1HI,8X,4HPDSO,8X,4HPDTO,8X,5HRENTO,7X,5HPRNTO,6X, 16HRENSO1,6X,6HRENSO2//16X,7HLB/SQFT//(1X,I3,4X,6E12.4))

1093 FORMAT(1H ,3X,1HI,7X,6HRENSO3,7X,3HHTO,9X,4HAHSO,8X,3HUOA,9X,4HHE 1AT//32X,13HBTU/HR/SQFT/F,14X,6HBTU/HR//(1X,I3,4X,5E12,4))

1051 FORMAT(27H TUBE WALL AVERAGE TEMP.= ,F10.2) 1052 FORMAT(28H SHELL SIDE AVERAGE TEMP.= ,F10.2) 1053 FORMAT(1H 34HP STRESS AT TUBE OD AND TUBE ID = ,2F10.2,1X, 19H(LB/SQIN),//,18H(SHOULD NOT EXCEED,F10.2,3H)) 1054 FORMAT(1H 36HP+Q STRESS AT TUBE OD AND TUBE ID = ,2F10.2,1X, 19H(LB/SQIN),//,18H(SHOULD NOT EXCEED,F10.2,3H)) 1055 FORMAT(1H 38HP+Q+F STRESS AT TUBE OD AND TUBE ID = , 12F10.2,1X,9H(LB/SQIN),//,18H(SHOULD NOT EXCEED,F10.2,3H)) C

C READ IN AND PRINT OUT INPUT DATA

KEY7=1

VM1(1)=0.

VM2(1)=0.

VM3(1)=0.

VWO1(1)=0.

VWO3(1)=0.

RENSO1(1)=0.

RENSO2(1)=0.

RENSO3(1)=0.

HSO1(1)=0.

HSO2(1)=0.

HSO3(1)=0.

HEFI=1.

HEFO=1.

С

1 CONTINUE

HSFCT=1.

IF(FTO.LT.CTO) HSFCT=-1.

open (5,file='output.txt')

write (5,1008) HEATL

C write (5,1007) (K,CTM(K),CASM(K),K=1,ICNPT)

write (5,1009) PRDT write (5,1010) PRDS write (5,1011) TPIN write (5,1012) SPOUT write (5,1013) CTO write (5,1014) FTO write (5,1015) ETF write (5,1016) ETC write (5,1017) LK write (5,1018) PLK write (5,1019) WCOND write (5,1020) ARC write (5,1021) RA5 write (5,1022) DTR write (5,1023) RA8MAX write (5,1024) KASES

write (5,1025) KENTB

write (5,1026) KTBST

write (5,1027) DIA

write (5,1028) WTHK

write (5,1029) RPI

write (5,1030) BCPI

write (5,1031) CUT3

write (5,1032) CUT4

- C BEGIN GEOMETRY CALCULATIONS FOR SINGLE ANNULUS COUNTER FLOW
- C DISC AND DOUGHNUT BAFFLED HEAT EXCHANGER

ARCR=0.017453*ARC

ATUBE=(3.14159*(DIA**2.0))/4.0

GFTT=1./3600.

GFT=1./144.

DIAI=DIA-2.0*WTHK

FATUB=(3.14159*(DIAI**2.0))/4.0

KEY1=0

PERC1=0.99

2 IF(KEY1.GT.0) BSOI=0.5*(BSL+BSH)

KEY2=0

PERC2=0.99

RA8L=RA5

RA8H=RA8MAX

3 RA8=0.5*(RA8L+RA8H)

RJ8=(RA8-RA5-2.*DTR)/RPI+1.

IJ8=RJ8

RIJ8=IJ8

IF(RJ8-RIJ8-0.5)4,4,5

4 J8=IJ8

TRPI=(RA8-RA5-2.*DTR)/(RIJ8-1.)

CPI=BCPI*RPI/TRPI

GOTO 6

5 J8=IJ8+1

TRPI=(RA8-RA5-2.*DTR)/RIJ8

CPI=BCPI*RPI/TRPI

6 DO 7 I=1,J8

R(I)=RA5+DTR+TRPI*(I-1)

FACT(I)=6.28318*R(I)

NT(I)=FACT(I)/CPI

TCPI(I)=FACT(I)/NT(I)

IF(I.EQ.1) TOTAL(I)=NT(I)

IF(I.NE.1) TOTAL(I)=TOTAL(I-1)+NT(I)

7 CONTINUE

NTO=TOTAL(J8)

SNT=NTO

RA52=RA5**2

RA82=RA8**2

RA6=(RA52+CUT4*(RA82-RA52))**.5

J6=(RA6-R(1))/TRPI+1.

RA6=R(J6)+.5*TRPI

RA7=(RA82-CUT3*(RA82-RA52))**.5

J7=(RA7-R(1))/TRPI+1.

RA7=R(J7)+.5*TRPI

RA62=RA6**2

RA72=RA7**2

RB1=0.5*(J8-J7)

RB2=J7-J6

RB3=0.5*J6

SUM1=TOTAL(J8)-TOTAL(J7)

SUM2=TOTAL(J7)-TOTAL(J6)

SUM3=TOTAL(J6)

ISUM1=SUM1

ISUM2=SUM2

ISUM3=SUM3

BSMAX=1.5*((RA8-(RA8-RA7)/2.)-(RA5+(RA6-RA5)/2.))

BSMIN=0.2*(RA8-RA5)

IF(BSMIN.LT.0.1667) BSMIN=0.1667

APO1=3.14159*(RA82-RA72)-ATUBE*SUM1

APO3=3.14159*(RA62-RA52)-ATUBE*SUM3

LAWO1=6.28318*RA7-.5*DIA*(NT(J7)+NT(J7+1))

LAWO3=6.28318*RA6-.5*DIA*(NT(J6)+NT(J6+1))

HW=2.*WCOND/(DIA*(ALOG(DIA/DIAI)))

! CSPHAV=0.36

! FSPHAV=0.324

CSPHAV=0.45

FSPHAV=0.568

! 0.45 : Avg. Cp of LiF-NaF-KF(Secondary Salt)

! 0.568 : Avg. Cp of LiF-BeF2 (Primary Salt)

QC=HEATL/(CSPHAV*(CTO-ETC))

QF=HEATL/(FSPHAV*(FTO-ETF))

GTO=QF/(NTO*FATUB)

KEY3=0

XPRMAX=6.0

XPRMIN=0.

8 EXPRAD=0.5*(XPRMIN+XPRMAX)

IF(KTBST.EQ.0) EXPRAD=1.77

IF(KEY1.EQ.0) BSH=BSMAX

IF(KEY1.EQ.0) BSL=BSMIN

IF(KEY1.EQ.0) BSOI=0.5*(BSL+BSH)

CURVES=0.069813*ARC*EXPRAD+0.4*(RA8-RA5)+.25*BSOI

IT=0

KFINAL=0

9 I=1

TSUM=0.

SSUM=0.

THEATO=0.0

TPDTO=0.0

TPDSO=0.

TFO(I)=FTO

TCI(I)=CTO

TIF=-5.0

TIC=-5.0

CDTF=0.

FDTF=0.

BSO=BSOI

BRL1=BSO/((RA8-(RA8-RA7)/2.)-(RA5+(RA6-RA5)/2.))

GBRL=0.77*BRL1**(-.138)

AWO1=BSO*LAWO1

AWO3=BSO*LAWO3

AW1=SQRT(AWO1*APO1)

- AW2=(AWO1+AWO3)/2.
- AW3=SQRT(AWO3*APO3)
- GSO1=QC/AW1
- GSO2=QC/AW2
- GSO3=QC/AW3
- BSO=CURVES
- EQVBSO=CURVES+13.*(DIA+DIAI)
- KEY4=0
- 10 KEY5=0
- 11 ATC=TCI(I)+(TIC/2.0)
 - CFT=ATC+CDTF*HSFCT
 - ATF=TFO(I)+TIF/2.
 - FFT=ATF-FDTF*HSFCT
 - FI=I
 - TUBLN(I)=(FI-1.)*BSOI+CURVES

- C Temeprature conversion form C to F
 - ATCT=0.55*(ATC-32.)
 - CFTT=0.55*(CFT-32.)
 - ATFT=0.55*(ATF-32.)
 - FFTT=0.55*(FFT-32.)
- CVIS=0.2121*EXP(4032./(460.+ATC))
 CVIS=2.4161*(0.04*EXP(4170./(273.+ATCT)))
 ! 2.4161 : CONVERSION FACTOR, FROM cP TO lb/ft*hr
- ! CVISW=0.2121*EXP(4032./(460.+CFT)) CVISW=2.416*(0.04*EXP(4170./(273.+CFTT)))
- ! CDEN=141.37-0.02466*ATC
 - CDEN=62.43*(2.53-0.00073*ATCT)
 - ! 62.43 : CONVERSION FACTOR, FROM g/m**3 TO lb/ft**3

! CCON=0.240

CCON=0.5779*1.

! 0.5779 : CONVERSION FACTOR, FROM W/mK TO Btu/hr ft f

! "Nuclear Sytems" Vol 1. pp 644

! CSPH=0.36

CSPH=0.45

- ! FVIS=0.2637*EXP(7362./(460.+ATF)) FVIS=2.416*(0.116*EXP(3755./(273.+ATFT)))
- ! FVISW=0.2637*EXP(7362./(460.+FFT)) FVISW=2.416*(0.116*EXP(3755./(273.+FFTT)))
- ! FDEN=234.97-0.02317*ATF FDEN=62.43*(2.28-0.000488*ATFT)
- ! FCON=0.70

FCON=0.5779*1.1

! FSPH=0.324

FSPH=0.568

- C write(5,*) CVIS
- C write CVISW
- c write CDEN
- c write FVIS
- c write FVISW

VISK=(CVIS/CVISW)**0.14

FVISK=(FVIS/FVISW)**0.14

DCVIS=DIA/CVIS

CCDEN=1./CDEN

QCCDEN=QC*CCDEN

- C CALCULATE REYNOLDS AND PRANDTL NUMBER TUBE SIDE
 - RENTO(I)=DIAI*GTO/FVIS
 - PRNTO(I)=FVIS*FSPH/FCON
 - IF((KENTB.EQ.1).AND.(RENTO(I).GT.1001.).AND.(I.NE.1))
 - 1 HEFI=1.+((RENTO(I)-1000.)/9000.)**0.5
 - PDTO(I)=(.0028+.25*RENTO(I)**(-.32))*EQVBSO*GTO**2*HEFI/(DIAI*FDEN
 - 1 * 417182400.)
- C CALCULATE HEAT TRANSFER COEFFICIENT TUBE SIDE
 - HTO(I)=FCON/DIAI*.0217*(RENTO(I)**.8)*(PRNTO(I)**.3333)*FVISK*HEFI

GOTO 15

- 12 IF(RENTO(I).LT.2100.) GOTO 14
- 13 HTO(I)=FCON/DIAI*.089*(RENTO(I)**.6666-125.)*(PRNTO(I)**.3333)
- 1 *FVISK*HEFI*(1.+.3333*(DIAI/TUBLN(I)**.6666))

GOTO 15

- 14 HTO(I)=FCON/DIAI*(4.36+(0.025*RENTO(I)*PRNTO(I)*DIAI/TUBLN(I))/(1.
- 1+0.0012*RENTO(I)*PRNTO(I)*DIAI/TUBLN(I)))

15 IF(I.EQ.1) GOTO 16

- C CALCULATE FLOW AREAS SHELL SIDE
 - VWO1(I)=QCCDEN/AWO1
 - VWO3(I)=QCCDEN/AWO3
 - VM1(I)=GSO1*CCDEN
 - VM2(I)=GSO2*CCDEN
 - VM3(I)=GSO3*CCDEN
- C CALCULATE PRESSURE DROPS SHELL SIDE
 - DP1=(1.+.6*RB1)*CDEN*VM1(I)**2
 - DP2=.6*RB2*CDEN*VM2(I)**2
 - DP3=(1.+.6*RB3)*CDEN*VM3(I)**2
 - RENSO1(I)=GSO1*DCVIS
 - RENSO2(I)=GSO2*DCVIS
 - RENSO3(I)=GSO3*DCVIS
 - IF((KENTB.EQ.1).AND.(RENSO2(I).GT.1001.))
 - 1 HEFO=1.+0.3*((RENSO2(I)-1000.)/9000.)**0.5
 - PDSO(I)=(DP1+DP2+DP3)*PLK*HEFO/834624000.
 - IF(I.EQ.2) PDSO(1)=PDSO(2)

C CALCULATE BJ FACTOR AND SHELL SIDE COEFFICIENT

BJ(1)=(0.346*RENSO1(I)**(-0.382))/GBRL BJ(2)=(0.346*RENSO2(I)**(-0.382))/GBRL BJ(3)=(0.346*RENSO3(I)**(-0.382))/GBRL HSO1(I)=(CSPH*GSO1*BJ(1)*((CCON/(CSPH*CVIS))**.66))*VISK/LK HSO2(I)=(CSPH*GSO2*BJ(2)*((CCON/(CSPH*CVIS))**.66))*VISK/LK

HSO3(I)=(CSPH*GSO3*BJ(3)*((CCON/(CSPH*CVIS))**.66))*VISK/LK

AHSO(I)=(((HSO1(I)*SUM1)+(HSO2(I)*SUM2)+(HSO3(I)*SUM3))/SNT)/HEFO

GOTO 17

16 PDSO(I)=0.

APO=3.14159*(RA82-RA52)-SNT*ATUBE

EQVDIA=4.*APO/(3.14159*SNT*DIA+6.24318*(RA8+RA5))

GSO=QC/APO

RENSO=GSO*DCVIS

PRESO=CVIS*CSPH/CCON

AHSO(I)=0.128*CCON*VISK*(12.*EQVDIA*RENSO)**0.6*PRESO**0.33/DIA

17 UOA(I)=1.0/((1.0/AHSO(I))+1.0/(DIA/DIAI*HTO(I))+(1.0/HW))

A=QF*FSPH

B=QC*CSPH

D=UOA(I)*SNT*BSO*3.14159*DIA

P=-HSFCT*(D*(A-B))/(A*B)

PBAR=EXP(P)

C=(B-A)*PBAR

TCO(I)=((TCI(I)*(B*PBAR-A))-(TFO(I)*A*(PBAR-1.)))/C

TFI(I)=((TCO(I)-TCI(I))*B/A)+TFO(I)

HEAT(I)=-A*(TFI(I)-TFO(I))

TWDT(I)=(HEAT(I)/NTO)*ALOG(DIA/DIAI)/(2.0*3.14159*BSO*WCOND)

CTIF=TFI(I)-TFO(I)

CTIC=TCO(I)-TCI(I)

CTX1=ABS(CTIF-TIF)

CTX2=ABS(CTIC-TIC)

IF(CTX1.LE.(3.0).AND.CTX2.LE.(3.0)) GOTO 18

TIF=CTIF

TIC=CTIC

KEY5=KEY5+1

IF(KEY5.GT.50) GOTO 37

GOTO 11

18 THEATO=THEATO+HEAT(I)

TPDTO=TPDTO+PDTO(I)

TPDSO=TPDSO+PDSO(I)

IF(I.EQ.2) TPDSO=TPDSO+PDSO(1)

CDTF=(((HEAT(I))/NTO)/BSO)/(3.14159*DIA*AHSO(I))

FDTF=CDTF*AHSO(I)/HTO(I)

FWT(I)=ATF-FDTF*HSFCT

CWT(I)=ATC+CDTF*HSFCT

AVWT(I)=0.5*(FWT(I)+CWT(I))

TSUM=TSUM+AVWT(I)

SSUM=SSUM+ATC

IF (KFINAL.EQ.1.AND.I.EQ.IT) GOTO 20

ETX1=ABS(ETF-TFI(I))

ETX2=ABS(TFI(I)-TFO(I))/2.

IF((ABS(ETX1).LE.ABS(ETX2)).OR.(TFI(I).LE.ETF)) GOTO 19

|=|+1

C write(5,*) I

IF(I.GT.1000) GOTO 30

IF(I.EQ.2) ATC1=ATC

TFO(I)=TFI(I-1)

TCI(I)=TCO(I-1)

BSO=BSOI

EQVBSO=BSO

KEY4=KEY4+1

IF(KEY4.GT.500000) GOTO 36

GOTO 10

19 KFINAL=1

IT=I

FIT=IT

DCURVE=CURVES*((HEATL-THEATO)/HEAT(1))

CURVES=CURVES+DCURVE

GOTO 9

20 TUBLEN=(FIT-1.)*BSOI+CURVES

HEXLEN=(FIT-1.)*BSOI+4.*EXPRAD*SIN(ARCR)+DCURVE+0.25*BSMAX

STRLEN=(FIT-1.)*BSOI+DCURVE+.25*BSMAX

21 IF(KTBST.EQ.0) GOTO 24

T1=FWT(1)

T2=CWT(1)

PDTO1=PDTO(1)

PDSO1=PDSO(1)

TSUM=TSUM-AVWT(1)

SSUM=SSUM-ATC1

TAVT=(CURVES*AVWT(1)+BSOI*TSUM)/TUBLEN

SAVT=((HEXLEN-BSOI*(FIT-1.))*ATC1+BSOI*SSUM)/HEXLEN

CALL TUBSTR (TPIN,SPOUT,PDT01,PDS01,T1,T2,

- 1 HEXLEN, EXPRAD, DIAI, DIA, ARC, SAVT, TAVT,
- 2 T11,T12,T13,T24,T25,T36,T37,T38,T49,T410,DT, BM,ASM,
- 3 ST,STP,SQP,SLPR,SLPG,SLLO,SLLI,STTO,STTI,TM,CASM,CTM,
- 4 P1,P2,SA,R1,R2,TL,RB, AA1,AA2,AA3,AA4,AA5,BB1,BB2,
- 5 BB3,BB4,BB5)

KEY3=KEY3+1

IF(KEY3.GT.1000) GOTO 35

IF((T24.LT.0.0).OR.(T12.LT. 0.0)) GOTO 22

IF((T24.GT.(.08*ASM)).AND.(T12.GT.(.08*ASM))) GOTO 23

GOTO 24

22 XPRMIN=EXPRAD

GOTO 8

23 XPRMAX=EXPRAD

GOTO 8

24 VOL = 0.7854*(DIAI**2.0)*NTO*TUBLEN

C CHECK OF TUBE AND SHELL PRESSURE DROPS

KET2 = KEY2 + 1

IF(PERC2.LE.0.1) GOTO 33

IF(TPDTO.LT.(PERC2*PRDT)) GOTO 25

IF(TPDTO.GT.PRDT) GOTO 26

GOTO 27

25 IF(RA8.LE.(RA5+0.005)) GOTO 34

RA8H =RA8

IF(KEY2.NE.30)GOTO 3

RA8L=RA8L-0.2

PERC2=PERC2-0.01

KEY2=10

GOTO 3

26 IF(RA8.GE.(RA8MAX-0.005)) GOTO 34

RA8H=RA8H+0.2

PERC2 = PERC2 - 0.01

KEY2=10

GOTO 3

27 KEY1=KEY1+1

IF(PERC1.LE.0.1) GOTO 32

IF(TPDSO.LT.(PERC1*PRDS)) GOTO 28

IF(TPDSO.GT.PRDS)GOTO 29

GOTO 38

28 IF(BSOI.LE.(BSMIN+0.005))GOTO 31

BSH =BSOI

IF(KEY1.NE.30)GOTO 2

BSL=BSL-0.1

PERC1=PERC1-0.01

KEY1=10

GOTO 2

29 IF(BSOI.GE.(BSMAX-0.005)) GOTO 31

BSL =BSOI

IF(KEY1.NE.30) GOTO 2

BSH=BSH+0.1

PERC1= PERC1 - 0.01

KEY1=10

GOTO 2

С

C PRINT EXIT SIGNALS

30 write (5,1057) BSO

1057 FORMAT(39H1BAFFLE SPACINGS EXCEEDE 75 WITH BSO = ,F5.2,2X,4H(FT))

GOTO 38

31 write (5,1058)

1058 FORMAT(20H1BSOI = MAX. OR MIN.)

GOTO 38

32 write (5,1059)

1059 FORMAT(48H1 PERC1 FOR SHELL PRESSURE DROP IS LESS THEN 0.1)

GOTO 38

33 write (5,1060)

1060 FORMAT(48H1 PERC2 FOR TUBE PRESSURE DROP IS LESS THEN 0.1)

GOTO 38

34 write (5,1061)

1061 FORMAT(29H1 SHELL RADIUS = MAX. OR MIN.)

GOTO 38

35 write (5,1062) KEY3

1062 FORMAT(6H1KEY3= ,I5)

GOTO 38

36 write (5,1063) KEY4

1063 FORMAT(16HERROR!! KEY4 = ,15,//)

GOTO 38

37 write (5,1064) KEY5

1064 FORMAT(6H1KEY5= ,I5)

GOTO 38

С

C END OF CASE, PRINT OUTPUT

38 DO 39 I = 1,IT

V1(I) = VM1(I)*GFTT

V2(I) = VM2(I)*GFTT

V3(I) = VM3(I)*GFTT

VW1(I) = VWO1(I)*GFTT

vw3(I) = VWO3(I)*GFTT

39 CONTINUE

TTDSO = TPDSO*GFT

TTDTO = TPDTO*GFT

TPPERC=TPDTO*100./PRDT

SPPERC=TPDSO*100./PRDS

HTPERC=100.*THEATO/HEATL

AREA=3.1459*DIA*SNT*TUBLEN

ASM3=3.*ASM

PSTO=AA1

PQSTO=AA2

PQFSTO=AA3

PSTI=BB1

PQSTI=BB4

PQFSTI=BB5

С

write (5,1033) THEATO,HTPERC write (5,1034) QC write (5,1035) QF write (5,1036) TTDSO,SPPERC write (5,1037) TTDTO,TPPERC

SUBROUTINE TUBSTR(TPIN,SPOUT,PDT01,PDS01,T1,T2,

```
1 HEXLEN, EXPRAD, DIAI, DIA, ARC, SAVT, TAVT,
```

```
IF(KEY7.GT.KASES)GOTO 41
```

KEY7=KEY7+1

40 CONTINUE

С

LOOP FOR ADDITIONAL CASES IF REQUIRED

GOTO 1 41 CONTINUE STOP END

write (5,1053) PSTO,PSTI,ASM write (5,1054) PQSTO,PQSTI,ASM3 write (5,1055) PQFSTO,PQFSTI,SA

1(I),I=1,IT)

close(5)

write (5,1038) RA8 write (5,1039) BSOI write (5,1040) VOL write (5,1041) AREA write (5,1042) SNT write (5,1043) TUBLEN write (5,1044) HEXLEN write (5,1045) STRLEN write (5,1046) EXPRAD write (5,1047) GBRL write (5,1051) TAVT write (5,1052) SAVT

write (5,1090)(I,TCI(I),TCO(I),CWT(I),TFI(I),TFO(I),FWT(I),I=1,IT) write (5,1091) (I,TWDT(I),V1(I),V2(I),V3(I),VW1(I),VW3(I),I=1,IT)

write(5,1092)(I,PDSO(I),PDTO(I),RENTO(I),PRNTO(I),RENSO1(I),RENSO2

write (5,1093) (I, RENSO3(I),HTO(I),AHSO(I),UOA(I),HEAT(I),I=1,IT)

С

- 2 T11, T12, T13, T24, T25, T36, T37, T38, T49, T410, DT, BM, ASM,
- 3 ST,STP,SQP,SLPR,SLPG,SLLO,SLLI,STTO,STTI,TM,CASM,CTM,
- 4 P1, P2, SA, R1, R2, TL, RB, AA1, AA2, AA3, AA4, AA5, BB1, BB2, BB3, BB4, BB5)
- DIMENSION CASM(6),CTM(6)

GFT=1./144.

- P1=(TPIN-.5*PDTO1)*GFT
- P2=(SPOUT +.5*PDSO1)*GFT
- R1=6.*DIAI

R2=6.*DIA

TL =12.*HEXLEN

RB=12.*EXPRAD

A=0.017452*ARC

CC DETERMINE AVERAGE CHANGE IN TEMPERATURE OF SHELL(DTS) AND TUBE(DTT)

DTS = SAVT-70.

DTT = TAVT-70.

CC CALCULATE PRESSURE AND TEMPERATURE DIFFERNTIAL ACROSS TUBE WALL

DP = P1-P2

DT = T1 - T2

CC AND AVERAGE TEMPERATURE OF TUBE WALL

TM = (T1+T2)/2.

C CALCULATE MOMENT OF INERTIA TUBE CROSSECTION(AMI)

AMI = 0.785298*(R2**4-R1**4)

CC CALL SUBROUTINE TO DETERMINE ALLOWABLE STRESS(ASW)

CALL LAGR (CASM,CTM,ASM,TM,2,6 ,IERR)

CC ESTABLISH MATERIAL PROPERTIES CONSTANTS

SA= 25000.0

EM = 2500000.0

PR = 0.3

TE = 0.0000078

SE = 0.0000076

CC CALCULATE AXIAL LOAD AND MOMENT DUE TO LOGITUDNAL EXPANSION

DY = TL*(TE*DTT-SE*DTS)

RM = (R2+R1)/2.

TW = R2-R1

AL = TW*RB/RM**2

AL2 = AL**2

AK = (1.+12.*AL2)/(10.+12.*AL2)

AA = 2.*A

P = 25000000.*AK*AMI*DY/(RB**3*(AA*COS(AA)-3.*SIN(AA)+4.*A))

BM = P*RB*(1.-COS(A))

CC CALCULATE Q STRESS DUE TO P

SQP = -P/(6.28318*RM*TW)

CC CALCULATE Q STRESS DUE TO M

B1 = 6./(5.+6.*AL2)

- B2 = BM/(AK*AMI)
- B3 = (R2/RM)**2

B4 = (R1/RM)**2

B5 = 1.5*RM*B2*AL*B1

SLLO = R2*B2*(1.-B1*B3)

- SLLI = R1*B2*(1.-B1*B4)
- STTO = B5*(1.-2.*B3)
- STTI = B5*(1.-2.*B4)
- CC CALCULATE F STRESS DUE TO TUBE WALL TEMPERATURE DROP
 - ST = 139.*DT

SLI = -ST

- STI = -ST
- SLO = ST
- STO = ST
- CC CALAULATE STRESS DUE TO PRESSURE
- CC HOOP

STP = DP*RM/TW

CC LONGITUDNAL

SLPR = STP/2.

SLPG = 0

CC RADIAL

SRPI = -P1

SRPO = -P2

CC P STRESS TUBE OD BEND OD

A11 =AMAX1(STP,SLPR,SRPO)

A12 =AMIN1(STP,SLPR,SRPO)

AA1 = A11-A12

T11 = ASM - ABS(AA1)

CC P+Q STRESS TUBE OD BEND OD

A13 =AMAX1(STP+STTO,SLPR+SQP+SLLO,SRPO)

A14 =AMIN1(STP+STTO,SLPR+SQP+SLLO,SRPO)

AA2 =A13-A14

T12 =3*ASM- ABS(AA2)

CC P+Q+F STRESS TUBE OD BEND ID

A15 =AMAX1(STP+STTO+STO,SLPR+SQP+SLLO+SLO,SRPO)

A16 =AMIN1(STP+STTO+STO,SLPR+SQP-SLLO+SLO,SRPO)

AA3 = A15-A16

T13 = SA - ABS(AA3)

- CC P STRESS TUBE OD DEND ID
- CC SAME AS P STRESS AT TUBE OD BEND OD T11)

СС

CC P+Q STRESS TUBE OD BEND ID

A22 =AMAX1(STP+STTO,SLPR+SQP-SLLO,SRPO)

A23 =AMIN1 (STP+STTO,SLPR+SQP-SLLO,SRPO)

AA4 = A22-A23

T24 = 3*ASM- ABS(AA4)

CC P+Q+F STRESS TUBE OD BEND ID

A24 =AMAX1(STP+STTO+STO,SLPR+SQP-SLLO+SLO,SRPO)

A25 =AMIN1(STP+STTO+STO,SLPR+SQP-SLLO+SLI,SRPO)

AA5 = A24-A25

T25 = SA - ABS(AA5)

CC P STRESS TUBE ID BEND OD

B11 = AMAX1(STP,SLPR,SRPI)

B12 = AMIN1 (STP, SLPR, SRPI)

BB1 = B11-B1

T36 = ASM- ABS(BB1)

CC P+Q STRESS TUBE ID BEND OD

B13 =AMAX1(STP+STTI,SLPR+SQP+SLLI,SRPI)

B14 =AMIN1(STP+STTI,SLPR+SQP+SLLI,SRPI)

BB2 = B13-B14

T37 = 3*ASM- ABS(BB2)

CC P+Q+F STRESS TUBE ID BEND OD

B15 =AMAX1(STP+STTI+STI,SLPR+SQP+SLLI+SLI,SRPI)

B16 =AMIN1(STP+STTI+STI,SLPR+SQP+SLLI+SLI,SRPI)

```
BB3 = B15-B16
```

T38 = SA -ABS(BB3)

- CC P STRESS TUBE ID BEND ID
- CC SAME AS P STRESS AT TUBE ID BEND OD -- T36
- СС
- CC P+Q STRESS TUBR ID BEND ID

B23 =AMAX1(STP+STTI,SLPR+SQP-SLLI,SRPI)

СС

B24 =AMIN1(STP+STTI,SLPR+SQP-SLLI,SRPI)

BB4 = B23-B24

T49 = 3*ASM- ABS(BB4)

CC P+Q+F STRESS TUBE ID BEND ID

B25 =AMAX1(STP+STTI+STI,SLPR+SQP-SLLI+SLI,SRPI)

B26 =AMIN1(STP+STTI+STI,SLPR+SQP-SLLI+SLI,SRPI)

BB5 = B25-B26

T410 = SA-ABS(BB5)

СС

СС

RETURN

END

SUBROUTINE LAGR (FX,X,FXP,XP,N,NPT,IER)

DIMENSION FX(NPT),X(NPT)

- C SUBROUTINE USES LARGRANGIAN INTERPOLATION TO A DESIRED DEGREE
- C POLYNOMIAL
- C FX = FUNCTION OF INDEPENDENT VARIABLES
- C X = INDEPENDENT VARIABLE
- C FXP = ESTIMATE OF FX AT XP
- C XP = VALUE OF X FOR WHICH INTERPOLATION IS DESIRED
- C N = DEGREE OF POLINOMIAL USED IN INTERPOLATION
- C NPT = NUMBER OF POINT-PAIRES IN TABLE
- C IER = COUNTER TO REPORT TYPE OF EXECUTION

С

C CHECK TO SEE IF XP IS A TABLE ENTRY

DO 2 K = 1 ,NPT

IF(XP.NE.X(K)) GOTO 2

1 FXP = FX(K)

IER = 3

RETURN

2 CONTINUE

C DETERMINE IF EXTRAPOLATION IS REQUIRED

IF(XP.LT.X(1)) GOTO 4

3 IF(XP.GT.X(NPT)) GOTO 5

GOTO 6

4 L1 = 1

L2 = NPT

GOTO 15

5 L1 = NPT - N

L2 = NPT

GOTO 15

6 IER = 2

C DETERMINE IF SUFFICIENT DATA IS PRESENT FOR DEGREE OF POLINOMIAL

M = N + 1

IF(M.LE.NPT) GOTO 8

7 IER = 1

RETURN

C DETERMINE NEXT HIGHEST POINT

8 DO 9 K = 2,NPT

K1 = K

IF(XP.LT.X(K)) GOTO 10

9 CONTINUE

C DETERMINE THE LOWER POINTS REQUIRED

10 L = M/2

11 L2 = K1+L-1

IF(L2.LE.NPT) GOTO 13

12 K1 = K1 - 1

GOTO 11

13 L1 = K1 + L -M

IF(L1)14,14,15

14 K1 = K1 + 1

L2 = L2 + 1

GOTO 13

- C INTERPOLATION BY LARGRANGIAM METHOD (SEE MATHMATICS OF PHYSICS
- C AND MODERN ENGINEERING , SOKOLNIKOFF AND REDHEFFER, PAGES 699,700)

15 FXP = 0.0

DO 18 K = L1,L2

PKX = 1.0

PKXK = 1.0

DO 17 I = L1,L2

IF(I.EQ.K) GOTO 17

16 PKX = PKX*(XP - X(I))

PKXK = PKXK*(X(K) - X(I))

17 CONTINUE

18 FXP = FXP + FX(K)*PKX/PKXK

RETURN

END

Appendix 2. Sample output

HEAT LOAD REQUIRED= 767731500. (BTU/HR) ALLOWABLE TOTAL TUBE-SIDE PRESSURE DROP= 3000. (LB/SQ-FT) ALLOWABLE TOTAL SHELL-SIDE PRESSURE DROP= 3000. (LB/SQ-FT) TUBE INLET PRESSURE= 25920. (LB/SQ-FT) SHELL OUTLET PRESSURE= 4896. (LB/SQ-FT) HIGH TEMP. OF SHELL SIDE FLUID= 1274.00 (F) HIGH TEMP. OF TUBE SIDE FLUID= 1300.00 (F) LOW TEMP. OF TUBE SIDE FLUID= 1112.00 (F) LOW TEMP. OF SHELL SIDE FLUID= 1013.00 (F) HEAT TRANSFER LEAKAGE FACTOR= .80000 PRESSURE LEAKAGE FACTOR= .52000 CONDUCTIVITY OF TUBE WALL METAL= 11.60000 (BTU/HR-FT-F) ARC OF FOUR BENDS FOR FLEXIBILITY= 60.00000 (DEGREES) INSIDE RADIUS OF OUTER ANNULUS= .90000 (FEET) DISTANCE BETWEEN SHELL WALL AND TUBES= .03125 (FEET) MAXIMUM ANTICIPATED OUTER RADIUS OF EXCHANGER= 4.00000 (FEET) NUMBER OF CASES RUN= 1 USE OF ENHANCED TUBES= 1 (ONE IF ENHANCED TUBES ARE USED) USE OF STRESS ANALYSIS SUBROUTINE= 0 (ONE IF TO BE USED) OUTSIDE DIAMETER OF TUBES= .03125 (FEET) WALL THICKNESS OF TUBES= .00438 (FEET) RADIAL PITCH= .06250 (FEET) CIRCUMFERENCIAL PITCH= .06250 (FEET) INNER BAFFLE CUT3= .40000 (PER CENT) INNER BAFFLE CUT4= .40000 (PER CENT)

TOTAL HEAT TRANSFERED= 759291500. (BTU/HR) (98.9 PERCENT) MASS FLOW RATE OF COOLANT= 6536667. (LB/HR) MASS FLOW RATE OF FUEL= 7189574. (LB/HR) SHELL-SIDE TOTAL PRESSURE DROP= 20.82 (LB/SQIN) (99.9 PERCENT) TUBE-SIDE TOTAL PRESSURE DROP= 20.17 (LB/SQIN) (96.8 PERCENT) NOMINAL SHELL RADIUS= 3.5500 (FT) UNIFORM BAFFLE SPACING = .6292 (FT) TUBE FLUID VOLUME CONTAINED IN TUBES= 105.65 (CUBIC FEET) TOTAL HEAT TRANSFER AREA BASED ON TUBE O.D. = 26145.44 (SQFT) TOTAL NUMBER OF TUBES= 9465. TOTAL TUBE LENGTH= 28.10 (FT) HEAT EXCH. APPROX. LENGTH= 26.18 (FEET) STRAIGHT SECTION OF TUBE LENGTH= 20.05 (FT) RADIUS OF THERMAL EXPANSION CURVES= 1.77 (FEET) BERGLIN MODIFICATION FACTOR= .87 TUBE WALL AVERAGE TEMP.= .00 SHELL SIDE AVERAGE TEMP.= .00

(SHOULD NOT EXCEED .00) P+Q STRESS AT TUBE OD AND TUBE ID = .00 .00 (LB/SQIN)

(SHOULD NOT EXCEED .00)

P+Q+F STRESS AT TUBE OD AND TUBE ID = .00 .00 (LB/SQIN)

(SHOULD NOT EXCEED .00)

1	TCI	TCO	CWT	TFI	TFO	FWT

F F F F F F

1	.1274E+04	.1257E+04	.1287E+04	.1288E+04	.1300E+04	.1288E+04
2	.1257E+04	.1253E+04	.1264E+04	.1285E+04	.1288E+04	.1269E+04
3	.1253E+04	.1248E+04	.1260E+04	.1281E+04	.1285E+04	.1266E+04
4	.1248E+04	.1243E+04	.1256E+04	.1278E+04	.1281E+04	.1262E+04
5	.1243E+04	.1239E+04	.1252E+04	.1275E+04	.1278E+04	.1257E+04
6	.1239E+04	.1234E+04	.1248E+04	.1271E+04	.1275E+04	.1253E+04
7	.1234E+04	.1228E+04	.1243E+04	.1267E+04	.1271E+04	.1249E+04
8	.1228E+04	.1223E+04	.1238E+04	.1263E+04	.1267E+04	.1244E+04
9	.1223E+04	.1218E+04	.1233E+04	.1259E+04	.1263E+04	.1239E+04
10	.1218E+04	.1212E+04	.1228E+04	.1255E+04	.1259E+04	.1234E+04
11	.1212E+04	.1206E+04	.1223E+04	.1251E+04	.1255E+04	.1229E+04
12	.1206E+04	.1200E+04	.1218E+04	.1246E+04	.1251E+04	.1224E+04

13	.1200E+04	.1193E+04	.1212E+04	.1242E+04	.1246E+04	.1219E+04
14	.1193E+04	.1187E+04	.1206E+04	.1237E+04	.1242E+04	.1213E+04
15	.1187E+04	.1180E+04	.1200E+04	.1232E+04	.1237E+04	.1207E+04
16	.1180E+04	.1173E+04	.1194E+04	.1227E+04	.1232E+04	.1201E+04
17	.1173E+04	.1166E+04	.1188E+04	.1222E+04	.1227E+04	.1195E+04
18	.1166E+04	.1158E+04	.1179E+04	.1217E+04	.1222E+04	.1187E+04
19	.1158E+04	.1151E+04	.1172E+04	.1211E+04	.1217E+04	.1180E+04
20	.1151E+04	.1143E+04	.1165E+04	.1205E+04	.1211E+04	.1173E+04
21	.1143E+04	.1134E+04	.1158E+04	.1199E+04	.1205E+04	.1166E+04
22	.1134E+04	.1126E+04	.1151E+04	.1193E+04	.1199E+04	.1159E+04
23	.1126E+04	.1117E+04	.1143E+04	.1187E+04	.1193E+04	.1151E+04
24	.1117E+04	.1108E+04	.1135E+04	.1181E+04	.1187E+04	.1143E+04
25	.1108E+04	.1099E+04	.1127E+04	.1174E+04	.1181E+04	.1135E+04
26	.1099E+04	.1090E+04	.1118E+04	.1167E+04	.1174E+04	.1126E+04
27	.1090E+04	.1080E+04	.1109E+04	.1160E+04	.1167E+04	.1118E+04
28	.1080E+04	.1070E+04	.1100E+04	.1153E+04	.1160E+04	.1109E+04
29	.1070E+04	.1060E+04	.1091E+04	.1146E+04	.1153E+04	.1100E+04
30	.1060E+04	.1049E+04	.1080E+04	.1138E+04	.1146E+04	.1089E+04
31	.1049E+04	.1038E+04	.1070E+04	.1130E+04	.1138E+04	.1079E+04
32	.1038E+04	.1027E+04	.1061E+04	.1122E+04	.1130E+04	.1069E+04
33	.1027E+04	.1016E+04	.1050E+04	.1114E+04	.1122E+04	.1059E+04
I	TWDT	V1	V2	V3	VW1	VW3

FT/SEC

F

1	.3005E+01	.0000E+00	.0000E+00	.0000E+00	.0000E+00	.0000E+00
2	.9683E+01	.1750E+01	.2826E+01	.1923E+01	.2604E+01	.3090E+01
3	.1001E+02	.1749E+01	.2824E+01	.1921E+01	.2602E+01	.3088E+01
4	.1038E+02	.1747E+01	.2821E+01	.1920E+01	.2600E+01	.3085E+01
5	.1076E+02	.1745E+01	.2819E+01	.1918E+01	.2597E+01	.3082E+01
6	.1114E+02	.1744E+01	.2816E+01	.1916E+01	.2595E+01	.3079E+01
7	.1154E+02	.1742E+01	.2813E+01	.1914E+01	.2592E+01	.3076E+01
8	.1195E+02	.1740E+01	.2811E+01	.1912E+01	.2590E+01	.3073E+01
9	.1237E+02	.1739E+01	.2808E+01	.1910E+01	.2587E+01	.3070E+01
10	.1280E+02	.1737E+01	.2805E+01	.1908E+01	.2584E+01	.3066E+01
11	.1325E+02	.1735E+01	.2802E+01	.1906E+01	.2581E+01	.3063E+01

12	.1370E+02	.1733E+01	.2798E+01	.1904E+01	.2578E+01	.3059E+01
13	.1417E+02	.1731E+01	.2795E+01	.1902E+01	.2575E+01	.3056E+01
14	.1465E+02	.1728E+01	.2791E+01	.1899E+01	.2572E+01	.3052E+01
15	.1514E+02	.1726E+01	.2788E+01	.1897E+01	.2569E+01	.3048E+01
16	.1564E+02	.1724E+01	.2784E+01	.1894E+01	.2565E+01	.3044E+01
17	.1615E+02	.1722E+01	.2780E+01	.1892E+01	.2562E+01	.3040E+01
18	.1665E+02	.1719E+01	.2776E+01	.1888E+01	.2557E+01	.3035E+01
19	.1718E+02	.1716E+01	.2772E+01	.1886E+01	.2554E+01	.3030E+01
20	.1772E+02	.1714E+01	.2768E+01	.1883E+01	.2550E+01	.3026E+01
21	.1827E+02	.1711E+01	.2763E+01	.1880E+01	.2546E+01	.3021E+01
22	.1883E+02	.1708E+01	.2759E+01	.1877E+01	.2542E+01	.3017E+01
23	.1939E+02	.1706E+01	.2755E+01	.1874E+01	.2538E+01	.3012E+01
24	.1996E+02	.1703E+01	.2750E+01	.1871E+01	.2534E+01	.3007E+01
25	.2054E+02	.1700E+01	.2745E+01	.1868E+01	.2529E+01	.3001E+01
26	.2112E+02	.1697E+01	.2740E+01	.1864E+01	.2525E+01	.2996E+01
27	.2171E+02	.1694E+01	.2735E+01	.1861E+01	.2520E+01	.2991E+01
28	.2231E+02	.1691E+01	.2730E+01	.1858E+01	.2516E+01	.2985E+01
29	.2290E+02	.1687E+01	.2725E+01	.1854E+01	.2511E+01	.2980E+01
30	.2347E+02	.1684E+01	.2719E+01	.1850E+01	.2505E+01	.2973E+01
31	.2407E+02	.1680E+01	.2714E+01	.1846E+01	.2500E+01	.2967E+01
32	.2466E+02	.1677E+01	.2708E+01	.1842E+01	.2495E+01	.2961E+01
33	.2525E+02	.1673E+01	.2703E+01	.1839E+01	.2490E+01	.2955E+01
I	PDSO	PDTO	RENTO	PRNTO	RENSO1	RENSO2

LB/SQFT

1	.9497E+02	.8122E+03	.3159E+04	.1216E+02	.0000E+00	.0000E+00
2	.9497E+02	.6559E+02	.3106E+04	.1237E+02	.3152E+04	.5090E+04
3	.9478E+02	.6558E+02	.3084E+04	.1246E+02	.3117E+04	.5033E+04
4	.9458E+02	.6557E+02	.3062E+04	.1255E+02	.3081E+04	.4975E+04
5	.9438E+02	.6556E+02	.3039E+04	.1265E+02	.3044E+04	.4915E+04
6	.9416E+02	.6555E+02	.3015E+04	.1274E+02	.3005E+04	.4854E+04
7	.9394E+02	.6554E+02	.2990E+04	.1285E+02	.2966E+04	.4790E+04
8	.9372E+02	.6552E+02	.2965E+04	.1296E+02	.2926E+04	.4725E+04
9	.9348E+02	.6551E+02	.2939E+04	.1307E+02	.2884E+04	.4658E+04
10	.9324E+02	.6550E+02	.2912E+04	.1319E+02	.2842E+04	.4589E+04

11	.9299E+02	.6549E+02	.2885E+04	.1332E+02	.2798E+04	.4519E+04
12	.9273E+02	.6547E+02	.2856E+04	.1345E+02	.2753E+04	.4447E+04
13	.9246E+02	.6546E+02	.2827E+04	.1359E+02	.2707E+04	.4372E+04
14	.9218E+02	.6545E+02	.2797E+04	.1374E+02	.2660E+04	.4296E+04
15	.9190E+02	.6543E+02	.2766E+04	.1389E+02	.2612E+04	.4219E+04
16	.9160E+02	.6542E+02	.2734E+04	.1406E+02	.2563E+04	.4139E+04
17	.9130E+02	.6541E+02	.2701E+04	.1423E+02	.2513E+04	.4058E+04
18	.9092E+02	.6539E+02	.2660E+04	.1444E+02	.2450E+04	.3957E+04
19	.9060E+02	.6538E+02	.2626E+04	.1463E+02	.2398E+04	.3873E+04
20	.9027E+02	.6536E+02	.2591E+04	.1483E+02	.2345E+04	.3787E+04
21	.8992E+02	.6535E+02	.2554E+04	.1504E+02	.2291E+04	.3700E+04
22	.8957E+02	.6533E+02	.2518E+04	.1526E+02	.2236E+04	.3611E+04
23	.8921E+02	.6532E+02	.2480E+04	.1550E+02	.2180E+04	.3521E+04
24	.8884E+02	.6530E+02	.2441E+04	.1574E+02	.2124E+04	.3429E+04
25	.8845E+02	.6529E+02	.2402E+04	.1600E+02	.2066E+04	.3337E+04
26	.8806E+02	.6527E+02	.2362E+04	.1627E+02	.2008E+04	.3243E+04
27	.8766E+02	.6526E+02	.2321E+04	.1656E+02	.1949E+04	.3148E+04
28	.8724E+02	.6524E+02	.2279E+04	.1686E+02	.1890E+04	.3052E+04
29	.8682E+02	.6522E+02	.2237E+04	.1718E+02	.1830E+04	.2955E+04
30	.8631E+02	.6520E+02	.2187E+04	.1757E+02	.1761E+04	.2844E+04
31	.8587E+02	.6518E+02	.2143E+04	.1793E+02	.1700E+04	.2746E+04
32	.8541E+02	.6517E+02	.2099E+04	.1831E+02	.1640E+04	.2648E+04
33	.8494E+02	.6515E+02	.2054E+04	.1871E+02	.1579E+04	.2550E+04
I	RENSO3	HTO	AHSO	UOA	HEAT	

BTU/HR

BTU/HR/SQFT/F

1	.0000E+00	.1191E+04	.3197E+03	.2395E+03	.5019E+08
2	.3463E+04	.1307E+04	.2264E+04	.6965E+03	.1278E+08
3	.3424E+04	.1296E+04	.2250E+04	.6930E+03	.1321E+08
4	.3385E+04	.1289E+04	.2246E+04	.6912E+03	.1370E+08
5	.3344E+04	.1281E+04	.2242E+04	.6893E+03	.1419E+08
6	.3302E+04	.1274E+04	.2237E+04	.6873E+03	.1470E+08
7	.3259E+04	.1266E+04	.2232E+04	.6852E+03	.1523E+08
8	.3215E+04	.1258E+04	.2227E+04	.6831E+03	.1577E+08
9	.3169E+04	.1250E+04	.2222E+04	.6808E+03	.1633E+08

10	.3122E+04	.1242E+04	.2217E+04	.6785E+03	.1690E+08
11	.3074E+04	.1233E+04	.2211E+04	.6761E+03	.1748E+08
12	.3025E+04	.1224E+04	.2205E+04	.6736E+03	.1808E+08
13	.2975E+04	.1214E+04	.2199E+04	.6710E+03	.1870E+08
14	.2923E+04	.1205E+04	.2193E+04	.6682E+03	.1933E+08
15	.2870E+04	.1195E+04	.2187E+04	.6654E+03	.1998E+08
16	.2816E+04	.1184E+04	.2180E+04	.6625E+03	.2063E+08
17	.2761E+04	.1174E+04	.2173E+04	.6594E+03	.2131E+08
18	.2692E+04	.1161E+04	.2163E+04	.6556E+03	.2197E+08
19	.2635E+04	.1149E+04	.2156E+04	.6523E+03	.2267E+08
20	.2577E+04	.1138E+04	.2148E+04	.6488E+03	.2338E+08
21	.2517E+04	.1126E+04	.2139E+04	.6453E+03	.2411E+08
22	.2457E+04	.1114E+04	.2131E+04	.6416E+03	.2484E+08
23	.2395E+04	.1101E+04	.2122E+04	.6378E+03	.2559E+08
24	.2333E+04	.1088E+04	.2112E+04	.6338E+03	.2634E+08
25	.2270E+04	.1075E+04	.2102E+04	.6296E+03	.2711E+08
26	.2206E+04	.1061E+04	.2092E+04	.6254E+03	.2788E+08
27	.2142E+04	.1047E+04	.2082E+04	.6209E+03	.2865E+08
28	.2076E+04	.1033E+04	.2071E+04	.6163E+03	.2944E+08
29	.2011E+04	.1018E+04	.2060E+04	.6115E+03	.3022E+08
30	.1935E+04	.1001E+04	.2046E+04	.6059E+03	.3097E+08
31	.1868E+04	.9861E+03	.2034E+04	.6007E+03	.3176E+08
32	.1802E+04	.9704E+03	.2021E+04	.5954E+03	.3254E+08
33	1735E+04	9544E+03	2008E+04	5899E+03	3332E+0899